

BEXAR METROPOLITAN WATER DISTRICT MATERIALS SPECIFICATIONS

Section 005 Cooper Tubing

005.1 Scope of Work/Description

This specification covers copper tubing in nominal sizes of 3/4", 1", 1-1/2" and 2".

005.2 General Requirements

1. Copper tubing shall be of the type commercially known as type "K" soft and conforms to ASTM Specifications B-88-49, or latest revision thereof.
2. 3/4" and 1" copper tubing shall be furnished in sixty-foot coils or one hundred-foot coils as specified; 1-1/2" shall be furnished in twenty-foot lengths, forty-foot coils or sixty-foot coils as specified, and 2" shall be furnished in twenty-foot lengths or forty-foot coils or sixty-foot coils as specified.

END OF SECTION