

# BEXAR METROPOLITAN WATER DISTRICT MATERIALS SPECIFICATIONS

---

## Section 022 Steel Water Pipe

---

### 022.1 Scope of Work/Description

This specification covers steel pipe 4-inches and larger in size and manufactured for the purpose of conveying water.

### 022.2 General Requirements

1. Except as otherwise modified or supplemented herein, AWWA Tentative Standard C202-60T, "AWWA Tentative Standard for Mill-Type Steel Water Pipe," or the latest revision thereof, shall govern component materials, manufacture, and testing of all pipe furnished under this specification.
2. Wall thickness, inside diameters, or outside diameters as appropriate shall be as specified.
3. Pipe shall be either Grade A or Grade B.
4. Pipe ends shall be beveled and suitable for field butt welding except as otherwise specified.
5. Pipe lengths shall be nominal 40 foot lengths except for specials or as otherwise specified.
6. Protective coating, if specified, shall conform to AWWA Standard C203-62, "AWWA Standard for Coal-tar Enamel Protective Coatings for Steel Water Pipe".

END OF SECTION