

BEXAR METROPOLITAN WATER DISTRICT MATERIALS SPECIFICATIONS

Section 035 Pressure Reducing Valve

035.1 Scope of Work

This specification covers pressure reducing valves of the water tight, globe style bodies with flange bodies in sizes of 1- inch through 36 - inch. Pressure ranges will be noted on the project plans or in purchase orders.

035.2 General Requirements

1. Valves furnished under this specification shall be manufactured by one of the following or approved equal.

Cla -Val
GA Industries
Watts
Singer
2. Valves shall be class 150 lb. (unless otherwise noted).
3. The valve furnished shall be cast iron globe body. Material for the valve body shall be in accordance with ASTM A-126B.
4. The valve shall have flanged ends. Flanges shall be faced and drilled in accordance with the latest revision of ASTM B16.1.
5. The main valve seat shall be provided with v-notch port sections.
6. All internal removable working parts shall be bronze.
7. The valve shall be repairable without removing the valve body from the line.
8. Valves shall be solenoid controlled or diaphragm operated, hydraulically actuated and shall open or close on electric signal to the solenoid pilot valve. The solenoid pilot valve shall be heavy duty waterproof construction in a NEMA IV enclosure.
9. The valve shall have an indicator rod that is an integral part of the valve to show the position of the diaphragm within the valve body. Valves shall be equipped with speed controls for regulating the speed of opening and closing.
10. The valve shall have a SPDT limit for both open and closed positions to perform the functions as indicated on the electrical plans or as otherwise indicated on the drawing.

11. All materials of construction must be certified in writing to A.S.T.M. Specifications as follows:

Body	All Accepted and Approved	Ductile Iron ASTM A536 Cast Steel ASTM A216 WCB Cast Iron ASTM A126 GR.B Ductile Iron ASTM A536
Doors	Both Accepted and Approved	Cast Steel ASTM A216 WCB Al. Bronze ASTM B148 C95200

12. Sealing Element Buna-N
13. Torsion Spring T316 Stainless Steel
14. Hinge Shaft T316 Stainless Steel?
15. Stop Shaft - T316 Stainless Steel
16. Exterior Paint - Epoxy Primer

The bidders shall submit with the proposal three sets of certified drawings showing the principal dimensions, general construction and material specification for each valve proposed.

END OF SECTION